






**North Dakota
Long Term Care
ASSOCIATION**

Kenneth Daily, LNHA
Sr. Life Safety Specialist
kenn@qissurvey.com

Life Safety Review & Updates



1




CMS

2

Compliance Expectation

- Know your facility!
- Understand the systems and frequency for inspection, testing and maintenance
- Test your stuff on-time
- Document
- Account for the repairs
- Have it readily available for AHJs




3

Life Safety Expectations Have Changed!

Facility Maintenance Managers typically are saddled with the responsibilities of many departments:

- Maintenance
- Plant Operations
- Projects
- Environmental Services
- Security
- Laundry
- Life Safety
- AND...




4

It's Not Business as Usual

Preparing for survey can be time-consuming, which may lead the facility manager to rely on the results of previous surveys as a guide on preparation for future surveys.

For example; if the last survey did not reveal any deficiencies with the fire alarm test report, then the facility manager may decide not to review the current reports for compliance.




5

WHO IS RESPONSIBLE?


THE OWNER IS RESPONSIBLE FOR Inspection, Testing and Maintenance

4.6.12.4 Any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature requiring periodic testing, inspection, or operation to ensure its maintenance shall be tested, inspected, or operated as specified elsewhere in this Code or as directed by the authority having jurisdiction.

4.6.12.5 Maintenance, inspection, and testing shall be performed under the supervision of a responsible person who shall ensure that testing, inspection, and maintenance are made at specified intervals in accordance with applicable NFPA standards or as directed by the authority having jurisdiction.



6



Grandfathered refers to conduct that receives the benefit of a grandfather clause, allowing this conduct to receive the treatment of prior laws or rules.

grandfather clause noun
 Definition of *grandfather clause*
 : a clause creating an exemption based on circumstances previously existing


Apply the Code

It does not matter how an earlier AHJ ruled (or not)..... The current AHJ must evaluate the situation and determine whether it is acceptable for continued use

7



2012 Life Safety Code

- Promulgated by the National Fire Protection Association which is not a government agency
- It is a PERFORMANCE CODE and Code addresses those construction, protection, and occupancy features necessary to minimize danger to life from the effects of fire, including smoke, heat, and toxic gases created during a fire.
- It is NOT a building code. It focuses on safety of all persons in a building by protecting them from fire, smoke and toxic fumes



8


NFPA
Codes adopted effective July 5, 2016
101 Chapter 19 – Existing
101 Chapter 18 -New Facilities

9

NFPA 101

- The 2012 101 LSC is structured:
- Introductory chapters, definition and applications (1-5)
- Core chapters (6-10)
 - Chapter 6 – Hazards
 - Chapter 7 – Egress
 - Chapter 8 – Fire Protection Features
 - Chapter 9 – Service/ Fire Protection
 - Chapter 10 – Interior Finish, Contents/Furnishings
- Occupancy chapters (11-42)
 - Healthcare chapters 18 and 19
- Chapter 43 – Renovations (NEW)
- Annex
 - Further explains code but is not agreed to by consensus so is not 'part of the code'



10


Additional NFPA Referenced Codes

- **NFPA 10** Standard for Portable Fire Extinguishers 2010
- **NFPA 13** Standard for Installation of Sprinkler Systems 2010
- **NFPA 25** Standard for the Inspection, Testing & Maintenance of Water Based Extinguishing Systems 2011
- **NFPA 54**, *National Fuel Gas Code*, 2012 edition.
- **NFPA 70** National Electrical Code 2011
- **NFPA 220** Standard on Types of Building Construction 2012
- **NFPA 72** National Fire Alarm Code 2010
- **NFPA 80** Standard for Fire Doors and Fire Windows 2010
- **NFPA 96** Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations 2011
- **NFPA 101A** Guide on Alternative Approaches on Life Safety 2013
- **NFPA 105**, *Standard for Smoke Door Assemblies and Other Opening Protectives*, 2010 edition.
- **NFPA 110** Standard on Emergency and Standby Power Systems 2010

11

NFPA 99 Health Care Facilities Code



- Standard became a Code with 2012 edition
- The code for professionals involved in the design, construction, maintenance, and inspection of health care facilities (NFPA 101 Chapter 18-19 facilities)
- Applies to new and existing healthcare facilities
- Unique because the code is based on Risk and an assessment as determined by the facility leadership






12

Fundamental Principles

- Multiple safeguards
 - No single feature relied upon
- Safeguards make sense
 - Based on occupancy and the ability of occupants
- Egress numbers
 - 2 means of egress unless to do so doesn't make sense
- Egress unobstructed
- Egress awareness

- Lighting
- Notification
 - Horn/ Strobes
- Vertical openings
 - Protected egress
- Testing and maintenance
 - Standards maintained

13

Reasons for Increased Oversight




Figure 1 The room of origin viewed from the corridor (2014)

- It seems that there is an unprecedented level of attention on LSC issues in long term care.
- 31 Deaths in two fires in 2003
 - Tennessee
 - Connecticut
- GAO reports on Nursing Home Fire Safety
 - Building is not sprinklered
 - Fire originates in patient sleeping area
 - Door to room of fire origin is not closed or is reopened during the fire
 - Patient known to be outside the danger area during the fire found dead inside the danger zone after the fire

14

Main Problem is “Time”

- Many residents cannot self-evacuate
- Delays in resident notification may occur
- Beds and care devices may need to be moved with residents
- People panic and behave differently in fire conditions
- Fire Protection, especially fire doors & smoke doors can buy some time



15

Why do we care about doors?

Door
closed and
latched



Door left
open

16

Burning Bush Blamed for Nursing Home Fire



October 3, 2004

MORaine, Ohio -- Fire investigators said a burning bush ignited the care facility, forcing senior citizens to evacuate. The fire happened at the Miami Shores of Moraine Rehabilitation and Nursing Home on Pinnacle Road in Moraine over the weekend.

Residents and neighbors saw fire and smoke billowing from the roof, while staff moved quickly to evacuate the 98 people living in the facility. Many of the patients were bedridden or wheelchair bound.

Nearly 40 ambulances were called to the scene to help transport the residents to other facilities. Ten of the patients were taken to area hospital because they were on ventilators. According to officials, most of the others were either sent home with family or relocated to other nursing centers.

The fire destroyed much of the front of the building. The fire chief said although the investigation continues, a preliminary damage estimate has been set at \$150,000.

17

Surviving Through a Disaster....



18



19



20

State Operations Manual
Appendix I
K Tags
Part I - Survey Procedures for Life Safety Code Surveys
I. Introduction
II. The Survey Tasks
Task 1 – Offsite Survey Preparation
Task 2 - Entrance Conference/Onsite Preparatory Activities
Task 3 - Orientation Tour
Task 4 - Information Gathering
Task 5 - Information Analysis and Decision Making
Task 6 - Exit Conference
III. Complaint Investigations
IV. Post Survey Revisits

21

North Dakota Leading K Tags (FFY25)

K Tag	Citation
K 712	Fire Drills
K 353	Sprinkler System - Maintenance and Testing
K 918	Electrical Systems - Essential Electric System
K 271	Discharge from Exits
K 324	Cooking Facilities
K 914	Electrical Systems - Maintenance and Testing
K 511	Utilities - Gas and Electric
K 291	Emergency Lighting
K 293	Exit Signage
K 341	Fire Alarm System - Installation
K 345	Fire Alarm System - Testing and Maintenance
K 321	Hazardous Areas - Enclosure
K 761	Maintenance, Inspection and Testing - Doors

22

Increasing Deficiency Numbers



Electrical Issues

- K 912 Circuit breakers
- K 913 GFCI
- K 914 Receptable ITM
- K 918 Generator ITM
- K 511 Electrical
- K 920 Power Strips
- K 921 PCREE Testing
- K 916 Annunciator

23

Survey Readiness

It is best to not frustrate a surveyor during a survey!


You can avoid frustrating a surveyor if you have all your documentation prepared in advance and ready to go when the surveyor requests to review it.



24

Survey Preparation

- LSC Binder— everything in one place
- Current survey cycle only
- Only retain test and inspection documents: Do not retain invoices; purchase orders; and other documents that are not ITM
- Archive older records
- Review past surveys and ensure that prior deficiencies are corrected
- Evacuation plans – correct, posted and staff familiar



25

Inspection, Testing & Maintenance (ITM)

- Look for items in each report that did not pass the test or inspection.
- Look for any item that was not tested due to inaccessibility. This is never acceptable.
- If a device fails, then needs to be repaired or replaced then retested!
- Retain documents that support a repair or a replacement of a failed device, proving it was repaired and retested; (staple the corrective document to the original test document)



26


Talking To a Surveyor

- "It's always been like that."
- "The last surveyor didn't have a problem with that."
- "The local fire department (or fire marshal) said it's okay."
- "We can get you that documentation"—when it doesn't exist.
- "Is that a new requirement? We've never done that before."



27


Survey Documentation



- Life Safety Facility Layout
- LSC Waivers/ FSES
- Building Occupancy Permit
- State/ Local Fire Inspection(s)
- Policies – Fire-Evacuation, Fire Watch, smoking, space heater (K 711, K346, K354, K781, K741)
- In-services (K923, K711) - Fire/disaster, O₂ safety, Fire Marshal
- Certificates for boilers and elevators
- Emergency Lighting w/ Battery Function (K291)
 - Monthly 30 sec. test
 - Annual 90 min. test
- Exit signs (K281)
 - Monthly
- Exit Lighting (K281)
 - Monthly
- Interior Finish K331

28


Survey Documentation



- Magnetic Door Hold-Open Locking Devices (K222)
 - Quarterly
- Delayed Egress Doors (K222)
 - Monthly
- Locking Doors (K222)
 - Monthly
- Corridor - Smoke doors (K363)
 - Annual
- Fire Door testing (K761)
 - Annual
- Elevator ITM (K531)
 - Monthly
- HVAC ITM (K511, K521)
 - Manufacturer recommendations
- HVAC Filter Replacement
 - Per manufacturer
- Fire and Smoke Damper Inspections K521
 - ITM every 4-years

29


Survey Documentation



- Sprinkler System (K353)
 - Quarterly/ Annual
- Sprinkler System (Wet) Pressure Gauge Reading (K353)
 - Monthly
- Sprinkler System (Dry) Pressure Gauge Reading (K353)
 - Weekly
- Sprinkler System Inventory (K353)
- Spare Sprinkler Heads (K353)
 - Quarterly
- Sprinkler System Head Inspection (K353)
 - Annual
- Sprinkler System Internal Inspection (K353)
 - Every 5-years
- Check Valve Test (K353)
 - Every 5-years
- Sprinkler System Dry System Pressure Testing (K353)
 - Every 3-years
- Dry System Pitch Test (K 353)
 - Every 3-years
- Sprinkler System Backflow Testing (K353)
 - Annual
- Sprinkler System Anti-freeze Testing (K353)
 - Annual
- Standpipe System -FDC (K353)
 - Every 5-years
- Fire Hydrants (K353)
 - Annual

30

Survey Documentation



36. Fire Pump (K 353)

- Annual ITM

37. Fire Pump- Diesel - Testing (K353)

- Weekly

38. Fire Pump- Electric - Testing (K353)

- Monthly

39. Kitchen Range Hood system Suppression System (K324)

- Semi-annual ITM

40. Kitchen Range Hood system Suppression System (K324)

- Monthly

41. Kitchen Range Hood System Cleaning (K324)

- At least semi-annual

42. Fire Alarm ITM (K345)

- Semi-annual and annual inspection/ testing

43. Smoke detectors (K347)

- At 1 year & every 2 years thereafter

44. Battery Operated Smoke Detectors

- Weekly

45. Fire extinguishers (K355)

- Monthly/ Annual

46. Fire Drills (K712)


- Monthly (one/month, per shift/per quarter)

47. Smoke/fire Barrier (K271) Inspection

- Quarterly

31

Survey Documentation



48. NFPA 99 Risk Assessment (K901)

49. Ground Fault Receptacles (K913)

- Recommended quarterly

50. Non-hospital Grade Receptacles (K914)

- Annual

51. PCREE Electrical Equipment (K921)

- Annual

52. Circuit Breaker ITM

- Annual

53. Generator Annual Maintenance (K918)

- Annual

54. Generator (K918)

- Weekly
- Monthly


55. Generator 36-month Loaded Exercise (K918)

56. Generator Diesel Fuel Testing (K918)

- Annual

57. Lp Fuel Reliability Letter (K918)

32



33

LSC Outline – 100s



General Requirements

Focus here is construction, building and renovation

34

NFPA 101 43.7 Change of Use



Healthcare specific for existing, fully-sprinklered facilities: A Change in Use of a space not exceeding 250 sq. ft. results in a hazardous room (> 50 sq. ft.) the requirements for new construction shall not apply. The room must have a door with a closer and may have a proper protective plate.

35

SNF Resident K 131/ K 133

- Focus is frequently on the expected 2-hour fire barrier between nursing center and non-conforming building.
- Remember too FRR door in this assembly
- The fire barrier also can be separating new from existing portions of a nursing center
- Fire barriers are complete without penetrations.
- Ensure all penetrations are fire-stopped



36

K161 Building Construction Type

- NFPA 101 Tables 18.1.6.2 and 19.1.6.2 list acceptable construction types (there are 5 types)
 - Type I and II – built with noncombustible materials
 - Type III, IV and V built with a combination of materials
- Remember that in Type I and II wood should not be used as a construction material in noncombustible facility



37

Survey of Building and Occupancy		Survey Information		Survey Results	
Building Name	Address	Survey Date	Surveyor	Building Type	Occupancy
10000	10000	10000	10000	10000	10000
<p>Construction Type</p> <p>The facility is a 3 story building with basement constructed in 1977. The additions were completed in 1994 and 1999. The original building and all additions were determined to be a Type II (000) and V (111) construction and was fully sprinklered.</p> <p>The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridor.</p>					

Survey Conducted using NFPA 101, Chapter 19 Existing Health Care Chapter

Construction Type

"The facility is a 3 story building with basement constructed in 1977. The additions were completed in 1994 and 1999. The original building and all additions were determined to be a Type II (000) and V (111) construction and was fully sprinklered."

"The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridor."

38

CONSTRUCTION TYPES	
<p>Pertains to the combustibility and fire resistance rating on certain structural components</p> <p>Type II (222)</p> <ul style="list-style-type: none"> The first number refers to the fire rating of the load bearing walls (interior and exterior) The second number refers to the fire rating of the columns, beams, girders, trusses The third number refers to the fire rating of the floor assembly 	



39

IBC Construction = NFPA Construction Type

TYPES OF CONSTRUCTION Comparisons of Various Classification Sources					
IBC/IFC:	UBC/IFC:	NFPA:	NFIRS:	BOCA:	SBC:
Type I-A	Type I-FR	I (443)	1	1-A	I
Type I-B	Type II-FR	I (332)	1	1-B	II
Type II-A	Type II-1 Hr.	II (222)	2	2-A	---
Type II-B	Type II-N	II (111)	3	2-B	IV-1 Hr.
Type III-A	Type III-1 Hr.	II (000)	4	2-C	IV-unp.
Type III-B	Type III-N	III (211)	5	3-A	Protected Ordinary
Type IV	Type IV (H.T.)	III (200)	6	3-B	Unprotected Ordinary
Type V-A	Type V-1 Hr.	IV (2HH)	2	4	III Heavy Timber
Type V-B	Type V-N	V (111)	7	5-A	Protected Combustible
		V (000)	8	5-B	Unprotected Combustible


IBC/IFC – International Building Code / International Fire Code
 UBC/IFC – Uniform Building Code / Uniform Fire Code
 NFPA – National Fire Protection Association
 NFIRS – National Fire Incident Reporting System
 BOCA – BOCA / National Building Code
 SBC – Standard / Southern Building Code

40

Health Care Construction Type

STORIES				
TYPE	1	2	3	4+
I(443)	X	X	X	X
I(332)	X	X	X	X
II(222)	X	X	X	X
II(111)	X	X	X	NP
II(000)	X	X	NP	NP
III(211)	X	X	NP	NP
III(200)	X	NP	NP	NP
IV(2HH)	X	X	NP	NP
V(111)	X	X	NP	NP
V(000)	X	NP	NP	NP

41



Building Construction

- If the building has a common wall with a nonconforming building, the common wall should be a fire barrier having at least a two-hour fire resistance rating constructed.
 - Does the separations extend from the floor slab below to the floor or roof slab above?
 - Does each section extend from exterior wall to exterior wall?
 - Are doors in 2-hr. fire wall
 - > 1 ½ Hr. fire door and
 - Positive latching, and
 - Self-closing or automatic closing, and
 - Door < 1/8 in. gaps between meeting edges of door pairs, and
 - provided with < 3/4 in. undercuts?

42

Windows

- CMS requires windows with the adoption of the life safety code in 2016, however they DO NOT have to operate or open.
- Some fire department do require operating windows for fire safety



43

Prohibition of Storage in Stair Towers

- Per NFPA 101 – 7.2.2.3 Usable Space. Enclosed, usable spaces within exit enclosures shall be prohibited, including under stairs
- Section 7.2.2.5.3 Open space within the exit enclosure shall not be used for any purpose that has the potential to interfere with egress
- An interior exit stairway or ramp shall not be used for any purpose other than as a means of egress and a circulation path



44


Fire and Smoke Barriers

- Fire barriers are the fire rated walls that separate or compartmentalize the nursing home
- When there is a nonconforming occupancy like assisted living or offices the wall separation must be at least 2hr
- The wall will be inspected for proper construction and to ensure that all penetrations are properly fire stopped.



45

Fire Barriers K 372



- Fire barriers are fire rated assemblies that separate or compartmentalize the nursing home
- When there is a nonconforming occupancy like assisted living or office adjacent the wall separation must be at least 2hr
- The wall will be inspected for proper construction and to ensure that all penetrations are properly fire stopped.

46


Smoke and Fire Wall Sealing Products



- One-part sealants (caulks)
- Putty
- Cementitious mortars and grouts
- Sprays (coatings)
- Intumescent wraps, pillows, bags, blocks, etc.

47

Problem?




48




Never Use Spray Foam Products



49



50



Interior Finishes

- Materials having a total thickness of greater than 1/28-inch applied directly to the surface of walls and ceilings must consider the flame spread rating of the materials applied.
- NFPA 101(12), Section 10.2.8.1, specifies in fully sprinklered facility, a Class C interior wall and ceiling finish materials are permitted where Class B is required. This allows for a relaxation of interior finish requirements in sprinkled buildings, meaning less stringent materials can be used in place of more stringent ones.

51

NFPA 101

19.7.2.2 Fire Safety Plan

- **Use of alarms**
 - Pull stations
 - Smoke detection
- **Transmission of signal**
 - Alarm connected
 - Contact 911
- **Response to alarm**
 - Defend in Place
 - RACE
 - Responsibilities of staff
- **Isolation of fire**
 - Compartmentalization
 - Close doors and windows
 - Use of sprinklers
- **Extinguishment of fire**
 - Sprinklers
 - Fire extinguishers (PASS)
- **Evacuation of area**
 - Immediate removal direct threat (R)
- **Evacuation of compartment**
 - Recuse through horizontal exit
 - Move to area of refuse
- **Evacuation floor/ building**
 - Horizontal/vertical
 - Transportation
- **Individual responsible to call emergency services (911)**

55

Duties of Personnel

- Exact duties of various personnel or staff members should be defined in your facility's Emergency Plan.
- Is your facility using Incident Command?
 - Specific assignments may include notifying the Fire Department; notifying the Administrator; keeping a roster of all residents in case evacuation is necessary; someone to meet the fire department; or someone to answer the phones



56

Fire Drills K712

- Simulation of emergency fire conditions.
- Fire drills include a fire alarm signal and confirming of the signal to the monitoring company
- Conducted monthly per shift for 4 drills on each shift per year.
 - One drill per shift per quarter.
 - Different locations in the facility
 - Differing time of drills on each shift (varied by an HOUR)
 - Differing days of the week including weekends.
 - All departments are involved.
 - Documented observations of staff response.
 - Equipment functioning, doors released, alarms sounding, staff monitor exits, etc.
 - Residents are not evacuated during the drill.
- Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms.
- Should use a coded announcement such as "CODE RED" then plain language "fire"

57

Fire Drill Report

FIRE DRILL REPORT	
Facility _____	
Notify Monitoring Company under Fire Department Plan To Drill <input type="checkbox"/> Yes <input type="checkbox"/> No	
DATE _____	Time _____
SQUAD 1-1-1 2013-1 2013-1 2013-1 (Circle One)	
What was the simulated incident?	
1. Was action taken to activate the fire alarm system?	CTYes CTNo
2. Was the appropriate announcement made to start all of it?	CTYes CTNo
3. Did announcements include location of drill?	CTYes CTNo
4. Was staff action appropriate in this situation?	CTYes CTNo
5. Were all control doors including nearest escape doors closed?	CTYes CTNo
6. Were areas of escape carefully observed at nearest escape?	CTYes CTNo
7. Did staff respond with appropriate fire fighting equipment?	CTYes CTNo
8. Did the system sound throughout the facility?	CTYes CTNo
9. Did staff maintain a controlled area until all clear announcement?	CTYes CTNo
10. Was all smoke or the heat been contained?	CTYes CTNo
11. Was a follow-up inspection call made to the responding unit?	CTYes CTNo
12. Was the staff's response measured in case of a real emergency?	CTYes CTNo
Verify that the signal was received by monitoring station	
Time Signal Sent _____	Time Signal Received _____
Contact monitoring company for information following drill or alarm test.	
REMARKS _____	
Signature and title of individual conducting the drill _____	

- Key to vary by at least 1 - hour month to month/ quarter to quarter
- Vary by day of the week, time of day and day within the month
- Verify the time signal initiated and time received - no less than 90 seconds
 - 1:15:42 pulled
 - 1:15:52 received

58

Fire Watch

- When the sprinkler system fails to work properly for more than 10 hours in a 24-hour period and does not provide continuous protection a fire watch will be initiated. A sprinkler system includes but is not limited to sprinkler heads, branch lines, water mains, water supply, etc.
- When the fire alarm system fails to work properly for more than 4 hours in a 24-hour period and does not provide continuous protection a fire watch will be initiated. A fire alarm system includes but is not limited to smoke detectors, heat detectors, alarms, annunciators, etc.

Fire Watch Training



What is a Fire Watcher ?

59

Fire Watch

- Every fire watch tour needs to be documented with the findings which will include the date, time, and staff initials of person(s) performing the watch. A fire watch tour is a continuous activity performed by having one or more assigned/trained staff walking the entire affected area of the system outage every 15 minutes. The tour monitors the facility through direct observation for possible signs of fire.
- This is often done when a fire alarm, fire sprinkler, standpipe, or other fire protection system is out of service due to damage or scheduled maintenance.
- The assignment of a person or persons for the express purpose of notifying the fire department, the building occupants; preventing a fire from occurring; extinguishing small fires; or protecting the public from fire or life safety dangers.



60

Fire Watch Orientation

- Review facility's current fire watch policy and procedure
- Understand R-A-C-E
- Be able to identify possible hazards including fire
- Be capable of documenting each tour of duty
- Be capable of carrying a cell phone and contacting 9-1-1 as necessary
- Sign off this training

Fire Watch Orientation Worksheet	
Name: _____ Date: _____	
1. Review the facility's current fire watch policy and procedure.	_____
2. Understand the R-A-C-E (Rescue, Alarm, Contain, and Evacuate) procedure.	_____
3. Be able to identify possible fire hazards in each area upon an initial tour.	_____
4. Review responsibility to complete the facility fire watch assignment and sign-off.	_____
5. Carry mobile phone and know how to contact 9-1-1.	_____
6. Sign off at the end of the fire watch assignment.	_____


I, _____, have read and understood the facility's policies and procedures outlined in this fire watch orientation and have met all the requirements of completing a fire watch as instructed.

Signature: _____ Date: _____

61

Space Heaters K 781

- NFPA generally prohibits the use of portable space heaters in healthcare occupancies
- According to the NFPA 101 portable space heaters are not allowed in any resident sleeping room or compartments.



62

Smoking Requirements K 741

- In health care occupancies where smoking is prohibited and signs are prominently placed at all major entrances, secondary signs with language that prohibits smoking shall not be required
- Facility should have a smoking policy that includes:
 - Where prohibited and posting with signs that read NO SMOKING
 - In health care occupancies where smoking is prohibited, and signs are prominently placed at all major entrances
 - Smoking by patients classified as not responsible shall be prohibited unless the patient is under direct supervision.
 - Ashtrays of noncombustible material and safe design shall be provided in all areas where smoking is permitted.
 - Metal containers with self-closing cover devices into which ashtrays can be emptied shall be readily available to all areas where smoking is permitted.
- Smoking by patients classified as not responsible shall be prohibited unless there is direct supervision.



63

Common Smoking Citations

- Dozens of cigarette butts on the ground
- Smoking by residents on O2
- Use of unacceptable ashtrays such as coffee cans, pop cans, various cups, the ground, etc.
- Smoking in unauthorized areas
- Individuals assessed as unsafe not being supervised
- Ashtrays emptied into trashcans or trash in the ashcan



64


Thermal Fuse Cannula

This advanced thermal fuse features a high-performance heat-resistant shield and flame-retardant construction, engineered to deliver superior protection for the airway in fire-prone environments. Designed to withstand extreme temperatures, it effectively prevents heat damage and reduces fire-related risks, ensuring optimal safety and reliability in critical conditions.



65

SECTION 2 – MEANS OF EGRESS K 200s



- Means of Egress
- Components
- Corridor walls (exit passage)
 - Corridor doors
 - Horizontal exits
 - Stairs (as appropriate)
 - Ramps
- Corridor width
- Number of exits
- Arrangement of exits
- Travel distance to exit
- Exit discharge
- Exit Illumination
- Exit Identification

66

Means of Egress K211

General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full instant use in case of emergency.



67

Corridor Walls/ Doors



- Corridors are separated from use areas by walls constructed to resist the passage of smoke.
- Corridor walls may terminate at the underside of ceilings where specifically permitted by Code.
- Charting and clerical stations, waiting areas, dining rooms, and activity spaces may be open to corridor under certain conditions specified in the Code.
- Ensure ceiling tiles are clipped when the ceiling is a fire rated assembly
- Ensure no holes, penetrations or non-approved openings in corridor walls and ceilings.

68

Corridor Walls/ Doors

- Vision panels in corridor walls or doors shall be fixed window assemblies in approved frames. There are no restrictions in the area and fire resistance of glass and frames.
- Exits
 - Access to exits shall be marked by approved, readily visible signs in all cases where the exit or way to reach exit is not readily apparent to the occupants.



- No exit
 - Any door, passage or stairway that is neither an exit nor a way of exit access that is located so that it is likely to be mistaken for an exit shall be identified by a sign that reads "No Exit"
 - The No Exit sign shall have the No in letter 2" high and the word Exit in letters 1" high.



69



Corridor Doors K363

- Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas resist the passage of smoke and are made of 1 3/4 inch solid-bonded core wood or other material capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the passage of smoke. Corridor doors and doors to rooms containing flammable or combustible materials have positive latching hardware.

70




Positive Latching Hardware

71


Exits

Monitor facility to ensure that:

- Exit are readily accessible at all times and that the means of egress is continuously maintained free of all obstructions or impediments.
- Exit and directional signs display the correct egress pathway or direction of travel with continuous illumination and are also served by the emergency lighting system.
- Exit discharges outside the building have a hard surface to the public way and that the exit discharge is usable during inclement weather and without impediments.
- Exit discharges outside of the building are illuminated along the path to the public way. Illumination must be a minimum of one foot candle at floor level by any source.



72



Means of Egress


- Exit discharge is arranged and provides a level walking surface with respect to changes in elevation and shall be maintained free of obstructions. Additionally, the exit discharge shall be a hard packed all-weather travel surface
- Walking surface must be level, clear, and unobstructed at all times and useable under all weather conditions
 - Abrupt changes in elevations shall not exceed 1/4in
 - Under 1/2in can be beveled
 - Over 1/2in must be corrected by other means

73

Corridor Width Requirements

Certain wheeled equipment are permitted in the corridor provided the following:

- The clear width of the corridor is never reduced to less than 5 feet (60")
- There is a written fire safety plan and training program that address the relocation of the wheeled equipment during a fire



74

Wheeled Items in the Corridor

<u>Permitted</u>	<u>Not Permitted</u>
• Food service carts in use	• Beds
• Housekeeping carts in use	• Trash containers greater than 32 gals
• Medication carts in use	• Desks
• Isolation carts in use	• Chairs
• Crash carts	• Tables
• Portable lift equipment	• Computers on wheels
• Transport equipment	• Linen Carts
	• Bird cages

75
